

ProClean Comm ERCLEAN-WT

New boilers and cooling systems

Description

ProClean Comm is for cleaning of new boilers and cooling systems on board new buildings. It will remove scale, rust, oil and grease at the same time from the systems. The product is recirculated through the system, using an external circulation pump.

Directions For Use/Applications & Dosage Rates General Cleaning

1. Fill with fresh water.
2. Add solution 5-10% strength of ProClean Comm.
3. Circulate through the system for 5 to 8 hours at the maximum temperature allowed by the system.
4. Drain system completely and flush the entire system and all compounds with fresh water until the effluent is clear.
5. Reinspect to determine the results of the cleaning process.
6. Refill system with distillate or good quality fresh water and dose the required amount of cooling or boiler water treatment.
7. Test system regularly to ensure chemical residuals are maintained with specific limits.

Boiler Water Treatment

Summary

- Beside rust removing it also removes oil and scale.
- Saves from time and labor

A) Organic Properties

Physical State (20°C): Liquid
Color : Transparent
Odor : Characteristic

B) Physical Properties

pH : 12,0 – 14,0
Molecular Weight : -
Flash Point : -
Density : 1,15-1,25 g/cm³ at 20 C°
Solubility : Soluble with water.

Storage Conditions

Storage : Store at moderate temperatures.
Packaging Type : 25-30-210 L. sealed plastic drums or barrels.
Storage Period : 3 years

Approvals & Certificates



Product No : SP-KS-299